

# CENTRAL MARIN FIRE DEPARTMENT



Developed by

Ruben Martin, Fire Marshal

Approved by

Scott Shurtz, Fire Chief

## Fire Protection Standard 205-A

### Illuminated Directory

Date: 8-21-2017

Revision: 8-21-2017

Page: 1 of 1

This standard has been developed for the purpose of clearly identifying and marking proper addresses pursuant to California Fire Code, Chapter 5, as adopted by ordinance by the City of Larkspur and the Town of Corte Madera.

- I. In addition to individual building suite or apartment numerals or letters, condominiums, apartment complexes, townhouses, mobile home parks and multiple commercial buildings shall have installed at points of entry, an illuminated directory sign.
- II. The directory sign shall consist of the following:
  - a. A plot plan showing private drives
  - b. Access Roads
  - c. Building locations with unit numbers and addresses.
  - d. Fire hydrant locations
  - e. Name of the complex
  - f. A reference point on the plot plan indicating the location of the directory
  - g. A north direction indicator
- III. The developer or the property owner shall submit to the Fire Department for review and approval a detailed plan showing size, materials, and method of construction, electrical components and wiring, and location of installation.
- IV. Figure 1 indicates the minimum dimensions of the directory.

Note: Existing buildings constructed prior to the effective date of this standard need not conform to the illumination requirement of this standard.

Figure 1

